



STC Test Report

Date : 2012-02-17
No. : HC296340

Page 1 of 1

Applicant(Code:CRF005) : Cribrol Filters Ltd
Rm 3108 31/F Eight Commercial Building
8 Sun Yip Rd
Chai Wan HK

Description of Sample(s) : One submitted sample said to be Diesel Oil collected after the Emulsion of Diesel Oil + water (80:20) filtered through the filter "Cribrol".

Date Sample(s) Received : 2012-02-16

Date Tested : 2012-02-16 to 2012-02-17

Investigation Requested : Water content after filtering through the filter "Cribrol"

Method(s) Used : By Karl Fischer

Test Result(s) :

Test Item(s)	Diesel Oil after filtering through the filter "Cribrol"
Water content	0.05% (w/w)



LAU Yuk Kuen, Joey
Authorized Signatory
Chemical and Food Department
For and on behalf of

The Hong Kong Standards and Testing Centre Ltd

***** End of Test Report *****

The Hong Kong Standards and Testing Centre Ltd.

10 Dai Wang Street, Taiipo Industrial Estate, N.T., Hong Kong

Tel: (852) 2666 1888 Fax: (852) 2664 4353 E-mail : hkstc@hkstc.org Homepage : www.stc-group.org

This report shall not be reproduced unless with prior written approval from The Hong Kong Standards and Testing Centre Ltd.
For Conditions of Issuance of this test report, please refer to the overleaf or Homepage.